

SIGHISOARA - valori medii determinate in urma analizelor de laborator in perioada 01/05/2019- 31/05/2019

Parametru de calitate	Unitatea de masura	Valoare determinata	Valoarea admisa conform Legii 458/2002	Metoda de analiza
Clor rezidual liber	mg/l	0.223	0,5	STAS 6364/78
Amoniu	mg/l	0.011	0,5	SR ISO 7150-1/2001
Aluminiu	µg/l	0.006	200	SR ISO 10566/2001
Conductivitate	µS/cm	292	2500	SR 27888/1997
Cloruri	mg/l	22.674	250	SR ISO 9297/2001
Culoare		Acceptabil	Acceptabil consumatorului si nici o modificare anormala	SR ISO 7887/97
Gust		Acceptabil	Acceptabil consumatorului si nici o modificare anormala	SR EN 1622/97
Miros		Acceptabil	Acceptabil consumatorului si nici o modificare anormala	SR EN 1622/97
Nitrati	mg/l	4.56	50	SR ISO 7890-3/2000
Nitriti	mg/l	<LD	0,5	SR ISO 6777/1996
Oxidabilitate	mgO2/l	1.46	5	SR ISO ISO 8467/2001
pH	Unitati de pH	7.6	6,5-9,5	SR ISO 10523/97
Sulfati	mg/l	19.54	250	STAS 3069/87
Turbiditate	UNT	0.19	5	SR ISO ISO 7027/2001
Duritate totala	°G		Minim 5	SR ISO 9963-2/2002
Fier total	µg/l		200	SR ISO 6332/96